

EXAMPLE

Notice of Unsafe or Unhealthful Conditions

U.S. Department of Labor



To: Job Corps center name Job Corps center address	Date Inspected: November 24, 2008	Date Issued: December 22, 2008	Control No. ATS case number
	Management Representative: Center Director's name	Employee Representative: N/A	Page 1 of 1
	Inspector: M. Jackson, CSP, CIH		
A safety and health inspection was conducted on the (office):	Job Corps center name		

Located at (address and room number): Job Corps center address

The following unsafe or unhealthful conditions existed at the time of the inspection:

Item No.	Standard/Code Violation/Description	Hazard Severity	Date Abatement Required	Abatement Action Taken	Date Action Taken	Abatement Plan Required	
						Yes	No
1	29 CFR 1910.304 Several vacuum cleaners in the dormitories are missing the ground prongs on the electrical plug.	Marginal	1/22/2009	New electrical cords were installed on the equipment that could be repaired. Vacuums that could not be repaired were removed from service and disposed of.	11/25/2008		X
2	29 CFR 1910.36(d) In the kitchen, the door from the dry storage room is equipped with a locking device. In the Material Handling Shop, Paint Shop, Carpentry Shop, Bricklaying Shop, and Welding Shop, rear exit doors to the outside are equipped with locking devices.	Imminent Danger	1/22/2009	Deadbolts were removed from all doors and Replaced with panic hardware.	12/19/2008		X